

COMMONWEALTH OF KENTUCKY  
BEFORE THE ENERGY REGULATORY COMMISSION

In the Matter of:

APPLICATION OF MRS. RONNIE MARSILLET, )  
BLUE RIVER, EKTNUCKY, TO DEVIATE FROM )  
COMMISSION REGULATION 807 KAR 50:045 ) CASE NO. 8029  
SECTION 6, SUBPART 6 )

O R D E R

On November 5, 1980, Mrs. Ronnie Marsillett, Blue River, Kentucky, filed a letter with the Commission requesting authority to use 1-1/4 inch plastic pipe in the construction of a service line to his property from a line of Kentucky West Virginia Gas Company.

The Commission decided to treat this letter as an application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 50:045 Section 6, Subpart 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various digging activities and recommended the granting of the requested authority.

The Commission, having considered the application, all evidence of record and being fully advised, is of the opinion and finds:

1. That a hearing to consider the merits of the application will not be necessary.

2. That Mrs. Marsillett should be granted permission to use 1-1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and the entire service line is plastic and is buried a minimum of 36 inches; and provided that the steel pipe encasement of the plastic be properly installed at the road crossing and creek crossing.

3. That the completed service line installation shall be inspected by Commission staff members prior to the filling of the ditch.

4. That Mrs. Marsillett shall notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. That this service line be used only to serve one (1) dwelling, as required by state law.

6. That the plastic pipe be installed by persons who qualify under O.P.S.O. requirements.


7. That Mrs. Marsillett shall meet all other requirements of Energy Regulatory Commission Regulation 807 KAR 50:045, Section 6 in her installations.


IT IS THEREFORE ORDERED that Mrs. Ronnie Marsillett, Blue River, Kentucky, be and she hereby is granted authority to deviate from Energy Regulatory Commission Regulation 807 KAR 50:045, Section 6, Subpart 6, and install 1-1/4 inch plastic pipe of an approved type for her service line, said pipe to be buried a minimum of 36 inches, with the road crossing and creek crossing installed with the proper steel encasement of the plastic pipe.


IT IS FURTHER ORDERED that Mrs. Marsillett notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of Utility Engineering and Services of the Energy Regulatory Commission before service is rendered.

Done at Frankfort, Kentucky, this 2nd day of December, 1980.

ENERGY REGULATORY COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Secretary